

City of Reno Purchasing Division P.O. Box 1900 Reno, NV 89505

Addendum # 1 Bid #1466 - Smoke Detectors posting May 23, 2013

All potential participants: Please note that for your proposal to be considered, you must sign and attach this addendum to your response. Failure to do so may be cause for disqualification of your response.

Question # 1

"Can you give me a model # for line item 1 (Hearing Impaired) detectors? Or if you can give us more specific details for this detector."

Answer # 1

The Reno Fire Department does not have a specific model or manufacturer for item 1 in this Bid. The only specifications for the smoke detectors is they must be ADA Compliant under NFPA 72 section 29.3.8.1 for "Mild to Sever Hearing Loss" which call for the use of an audible notification appliance that produces a 520 Hz square wave output instead of the use of visible notification appliances (strobes).

Question #2

"Will you accept a plug-in/battery backup, audible alert alarm and bed shaker for line Item 1?"

Answer #2

The Reno Fire Department will be conducting the installation of the smoke detectors and are not qualified electricians, therefore and "plug-in" unit must come wired to plug into an ordinary receptacle. In this case the City would accept "plug-in/battery backup" unit with bed shaker.

Question #3

"Would the City accept a standard smoke alarm along with a separate device to work together with it to make it ADA compliant?"

Answer #3

The City would consider a standard smoke alarm with a separate device but both would have to meet the power requirements as set forth in the bid specification.

FIRM NAME		

Please submit this signed and da	ated addendum with your proposals.	
I	of	
Print Name	Firm Name	
acknowledge receipt of Addenda	#1 (two pages) for Bid #1463. This add	endum
must be signed and returned with	n your documents.	
Si	ignature	Date

Matthew Taylor Senior Management Analyst